3 <sup>rd</sup> Party Damage	103-(Gen. Design), 111-(Design factor)	615–(Emerg. Plan)	Participation in state one-call system,
	317-(Hazard prot), 327-(Cover)		
	614-(Dam. Prevent), 616-(Public		Use of qualified operator employees
	education)		and contractors to perform marking
	705-(Patrol), 707-(Line markers)		and locating of buried structures and
	711 (Repair – gen.), 717-(Repair –		in direct supervision of excavation
	perm.)		work, AND
			Either monitoring of excavations near
			operator's transmission pipelines, or
			bi-monthly patrol of transmission
			pipelines in class 3 and 4 locations.
			Any indications of unreported
			construction activity would require a
			follow up investigation to determine if
		*	mechanical damage occurred.

- [